

## Regulations Governing Satellite Accumulation Areas

### RCRA ([40 CFR 262](#))

Waste is accumulated at or near the point of generation under the control of the operator.	262.15(a)
Container(s) have less than 55 gallons of Hazardous Waste.	262.15(a)
Container(s) have less than 1 quart or 1 kilogram of acutely hazardous waste.	262.15(a)
Container(s) are in good condition and non-leaking.	262.15(a)(1)
Waste is compatible with the container it is stored in.	262.15(a)(2)
Only compatible wastes are stored in each container and the container is separated from nearby incompatible materials.	262.15(a)(3)
Container is closed except when adding, removing, or consolidating waste or when temporary venting is necessary.	262.15(a)(4)
Container is marked with the words "Hazardous Waste" and an indication of the hazards of the contents.	262.15(a)(5)
Satellite area complies with all preparedness and prevention requirements noted below.	262.15(a)(8)
Area is maintained to prevent fire, explosions, and spills.	262.16(b)(8)(i)
Area must be equipped with: <ol style="list-style-type: none"> <li>1. Internal communications to signal to facility personnel.</li> <li>2. Communication device to alert local emergency response personnel.</li> <li>3. Fire extinguishers, spill control equipment, and decontamination equipment.</li> <li>4. Fire suppression, adequate water supply or foam producing equipment.</li> </ol>	262.16(b)(8)(ii)
Regular testing and maintenance of equipment is performed.	262.16(b)(8)(iii)
Immediate access to communication equipment when handling hazardous waste.	262.16(b)(8)(iv)
Adequate aisle space.	262.16(b)(8)(v)
Emergency information posted next to telephones or in areas directly involved in the generation and accumulation of hazardous waste.	262.16(b)(9)(ii)