



Purchasing Services Office

801 Leroy Place
Socorro, NM 87801
(575) 835-5886

Letter of Addendum

TO: All Offerors

FROM: Meradeth Montoya, Assistant Director of Purchasing

DATE: 07/29/2025

RE: RFP Number: RFB#26070005 Amendment No. 2
Commodity: Pre-Engineered Metal Building-NMT Drone Facility

Please Note: This amendment is issued to amend the RFB as detailed below

- Q1) What is the requested roof panel type/gauge/finish?
A1) Exposed fastener/26 gauge/Silicone Modified Polyester (SMP)
- Q2) What is the gauge and finish of the exterior walls?
A2) Exposed fastener/26 gauge/Silicone Modified Polyester (SMP) (tan color on walls white roof colors per plan)
- Q3) Will the interior be built out by others after erection or should we quote liner panels (common practice is to use 26 gauge PBR panels 8' up the walls).
A3) Interior panels are not required.

ALL OFFERORS ARE REQUIRED TO CONFIRM THE RECEIPT OF THIS AMENDMENT IN THEIR RESPONSE.
ALL OTHER TERMS AND CONDITIONS OF THE RFP REMAIN UNCHANGED.